

QA-Slab Foundation Pre-Pour Checklist

Section HB.02.00

Forms and Reinforcing

i Instructions. Take picture of plan title block on next checkpoint.

Foundation location, elevation, and dimensions verified to current version of plans.	<input checked="" type="checkbox"/>	QC	OPN	NA		
Observations						
Foundation depth in field per plan and code +/- 1/2" (no overdig).	FTQ	<input checked="" type="checkbox"/>	OPN	NA		
Observations						
Footer depth and width per plan and code.	<input checked="" type="checkbox"/>	QC	OPN	NA		
Observations						
Vapor barrier extends to form boards and sealed around penetrations	FTQ	QC	<input checked="" type="checkbox"/>	NA		
Observations						
Rebar and wire mesh diameter and number per specifications.	<input checked="" type="checkbox"/>	QC	OPN	NA		
Observations						

Other Trades

Number of electrical and plumbing risers match number on plan, locations verified:	<input checked="" type="checkbox"/>	QC	OPN	NA		
Observations						
Fall of waste lines verified with level, supported with backfill.	FTQ	<input checked="" type="checkbox"/>	OPN	NA		
Observations						
Backfill and underpinning installed under pipes where needed.	FTQ	QC	<input checked="" type="checkbox"/>	NA		
Observations						

General

i Take 6+ reference pictures from various positions to show overall foundation condition of foundation

Survey pictures of foundation prior to pour.		
Observations		